



# RICHEY BLVD FUEL TANK REPLACEMENT

MILLER O'HERN CONSTRUCTION  
395-9479 FAX 495-5139

## REQUEST FOR INFORMATION

RFI 1

DATE June 8, 2011

RESPONSE REQUIRED BY: June 14, 2011

SPECIFICATION SECTION: CONTRACT AGREEMENT ARTICLE XIX.B

PLANS SHEET:

QUESTION:

A. In Article XIX.B.d the technical specifications and plans are on the same level in the Order of Precedence. In the event of conflict between the two, which will override?

B. Additionally, there are three specification sections dealing with fuel piping and equipment - 2554, 2555 and 15192 - and notes on the plan sheets. There are duplications, inconsistencies and conflicts among these four sources of information. How are we to resolve the differences we find?

SUGGESTED ANSWER:

A. Normally, specifications override plans.

B. The fuel subcontractor will submit on a system basis, selecting from the various information sources, to provide a total system that meets the functional requirements of the project.

BY:

DATE:

8-Jun-11

---

RICHEY BLVD FUEL TANK  
REPLACEMENT

RFI 1

MILLER O'HERN CONSTRUCTION  
395-9479 FAX 495-5139

M3 RESPONSE:

Specifications shall supersede plans, however subcontractor to issue an RFI on any discrepancies for approval.

APPROVED:

Armando Navarro

DATE:

6/10/2011

PAGE 2